



Cherry Creek Fire Department  
5920 Cherry Creek Road  
Port Alberni BC V9Y 8R7  
Phone 250.723.2254

## Tender Addendum

To Be Distributed to all Current Interested Parties	
Date	September 26, 2024
Reference (Tender number)	T05-2024 – Electrical

The following Addendum is intended to communicate pertinent answers to questions posed by current applicants;

### Clarifications: Security:

1. Where electric strikes and card readers are required request to exit devices are required in order to sense forced door events.
2. Delete section 1 on page E04, this was written to support a fire alarm system which is no longer part of the project scope, and sorry for the confusion.
3. Additional notes for section 3 E04 as follows:
  - a) It is the intention of the project that the building support the addition of an intrusion detection system without requiring significant rewiring in finished walls.
  - b) Include wiring for a security keypad at the main entry.
  - c) Include wiring to support motion sensors in the truck bays and mess hall.
  - d) Include wiring for a sounding device.
  - e) Include a category cable from the network/data closet (under stairs) to the security panel for future system monitoring.
  - f) Make use of double output door contacts where door contacts are needed for the access control system.